

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
horizontal slider	2110 2111 2130 2130J 2170	59" x 47"	3/4"	1/8	1/8	-	x	<--	29	24	04/25/23	TL23-149
				1/8	3/16	-	x	<--	33	28	04/25/23	TL23-150
				1/8	LAM	-	-->	x	34	29	04/25/23	TL23-151
				3/16	3/16	-	x	<--	31	26	04/26/23	TL23-153
				3/16	1/4	-	-->	x	33	29	04/26/23	TL23-154
				1/4	1/4	-	-->	x	32	29	04/26/23	TL23-155
				1/4	LAM	-	-->	x	33	29	04/26/23	TL23-157
vertical slider	2210 2211 2230 2230J 2270	47" x 59"	3/4"	1/8	1/8	-	x	<--	30	25	08/23/23	TL23-331
				1/8	3/16	-	x	<--	33	29	08/23/23	TL23-333
				1/8	LAM	-	-->	x	33	29	08/23/23	TL23-334
				3/16	3/16	-	x	<--	31	28	08/23/23	TL23-336
				3/16	1/4	-	-->	x	32	29	08/23/23	TL23-338
				1/4	1/4	-	-->	x	32	30	08/24/23	TL23-339
				1/4	LAM	-	-->	x	34	31	08/24/23	TL23-340
fixed - slider frame	2310 2311 2331 2331J 2370	47" x 59"	3/4"	1/8	1/8	-	x	<--	28	24	05/12/23	TL23-214
				1/8	3/16	-	x	<--	32	27	05/12/23	TL23-215
				1/8	LAM	-	-->	x	33	29	05/12/23	TL23-216
				3/16	3/16	-	x	<--	31	27	05/12/23	TL23-217
				3/16	1/4	-	-->	x	34	30	05/12/23	TL23-218
				1/4	1/4	-	-->	x	33	29	05/12/23	TL23-219R1
				1/4	LAM	-	-->	x	35	30	05/12/23	TL23-220
fixed - step frame	2340 2341 2330 2330J	47" x 59"	1"	1/8	1/8	-	x	<--	29	24	04/25/23	TL23-141
				1/8	3/16	-	x	<--	33	26	04/25/23	TL23-142
				1/8	LAM	-	-->	x	34	28	04/25/23	TL23-143
				3/16	3/16	-	x	<--	31	24	04/25/23	TL23-144
				3/16	1/4	-	x	<--	34	28	04/25/23	TL23-145
				1/4	1/4	-	x	<--	32	27	04/25/23	TL23-146
				1/4	LAM	-	-->	x	34	28	04/25/23	TL23-147
fixed - FA/FC match	2350T 2351T 2360T 2375T	47" x 59"	7/8"	1/8	1/8	-	x	<--	29	24	05/11/23	TL23-207
				1/8	3/16	-	x	<--	33	26	05/11/23	TL23-208
				1/8	LAM	-	-->	x	34	29	05/11/23	TL23-209
				3/16	3/16	-	x	<--	32	27	05/11/23	TL23-210
				3/16	1/4	-	x	<--	33	28	05/11/23	TL23-211
				1/4	1/4	-	x	<--	32	27	05/11/23	TL23-212
				1/4	LAM	-	-->	x	35	30	05/11/23	TL23-213

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
awning (flat sash)	2410T 2411T 2430T 2470T	59" x 24"	7/8"	1/8	1/8	-	x	<--	29	25	08/22/23	TL23-314
				1/8	3/16	-	x	<--	32	28	08/22/23	TL23-315
				1/8	LAM	-	-->	x	33	29	08/22/23	TL23-328
				3/16	3/16	-	x	<--	30	26	08/22/23	TL23-318
				3/16	1/4	-	x	<--	33	29	08/22/23	TL23-319
				1/4	1/4	-	x	<--	32	28	08/22/23	TL23-320
				1/4	LAM	-	-->	x	32	28	08/22/23	TL23-322
casement (flat sash)	2510T 2511T 2530T 2570T	24" x 59"	7/8"	1/8	1/8	-	x	<--	30	26	08/22/23	TL23-323
				1/8	3/16	-	x	<--	34	30	08/22/23	TL23-324
				1/8	LAM	-	-->	x	35	30	08/22/23	TL23-325
				3/16	3/16	-	x	<--	33	27	08/22/23	TL23-326
				3/16	1/4	-	x	<--	35	30	08/22/23	TL23-327
				1/4	1/4	-	x	<--	35	30	08/23/23	TL23-329
				1/4	LAM	-	-->	x	37	32	08/23/23	TL23-330
sliding door	2610 2611 2630 2670	79" x 79"	1"	1/8	1/8	-	x	<--	30	24	08/24/23	TL23-342
				1/8	3/16	-	x	<--	34	27	08/24/23	TL23-341
				1/8	LAM	-	-->	x	36	29	08/24/23	TL23-346
				5/32	5/32	-	x	<--	30	23	11/18/24	TL24-197
				5/32	3/16	-	-->	x	33	27	11/18/24	TL24-196
				3/16	3/16	-	x	<--	32	26	08/24/23	TL23-344
				5/32	1/4	-	-->	x	34	28	11/18/24	TL24-199
				3/16	1/4	-	x	<--	34	28	08/24/23	TL23-345
				1/4	1/4	-	x	<--	33	27	08/24/23	TL23-343
1/4	LAM	-	-->	x	37	30	08/24/23	TL23-349				